

Did you know that your insulating gloves need to be tested per OSHA 1910.137? OSHA 1910.137 states, " Before first issue and every 6 months thereafter"

**OSHA Testing Requirements
1910.137, 1910.269, ANSI A92.2**

Personal Protective Equipment Testing Intervals

Type of Equipment	When to test
Rubber insulating line hose	Upon indication that insulating value is suspect
Rubber insulating covers	Upon indication that insulating value is suspect
Rubber insulating blankets	Before first issue and every 12 months thereafter
Rubber insulating gloves	Before first issue and every 6 months thereafter
Rubber insulating sleeves	Before first issue and every 12 months thereafter
Live Line Tools	2 year cycle
Insulating Aerial Devices	Every 1

ASTM/ANSI standards:

(CODE)	(SPECIFICATION)
A	RUBBER INSULATING GLOVES D120, F496
B	RUBBER INSULATING SLEEVES D1051, F496
C	RUBBER INSULATING BLANKETS D1048, F479
D	RUBBER INSULATING LINE HOSE D1050, F478
E	RUBBER INSULATING COVERS D1049, F478
G	LIVE LINE TOOLS F711
H	INSULATING PLASTIC GUARDS F712
I	INSULATING AERIAL DEVICES F914, ANSI A92.2